



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

---

Attn:

**Warren Ristine  
Erie 1 BOCES  
355 Harlem Road  
West Seneca, NY 14224**

5/6/2021

Phone: (716) 821-7440  
Fax: (716) 821-7037

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 4/22/2021. The results are tabulated on the attached data pages for the following client designated project:

**Potter Career & Tech. Ctr.**

The reference number for these samples is EMSL Order #012104137. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Phillip Worby, Environmental Chemistry  
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104137  
 CustomerID: ERIE51  
 CustomerPO: B41235-21  
 ProjectID:

Attn: **Warren Ristine**  
**Erie 1 BOCES**  
**355 Harlem Road**  
**West Seneca, NY 14224**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 4/22/2021 09:40 AM

Project: **Potter Career & Tech. Ctr.**

**Analytical Results**

**Client Sample Description** 6131 #1 / Receiving / Sink Faucet  
**Collected:** 4/17/2021 10:42:00 AM  
**Lab ID:** 012104137-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	2.63	1.00 µg/L	5/4/2021 KB	5/4/2021 20:40 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6132 #2 / 1st Floor Handicap Bathroom / Sink Faucet  
**Collected:** 4/17/2021 10:44:00 AM  
**Lab ID:** 012104137-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/4/2021 20:47 KB
-------	------	----	-----------	-------------	-------------------

**Client Sample Description** 6133 3 / Custodial Closet / Sink Faucet  
**Collected:** 4/17/2021 10:44:00 AM  
**Lab ID:** 012104137-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/4/2021 20:49 KB
-------	------	----	-----------	-------------	-------------------

**Client Sample Description** 6134 4 / Bottle Filler / Water Cooler  
**Collected:** 4/17/2021 10:45:00 AM  
**Lab ID:** 012104137-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/4/2021 20:51 KB
-------	------	----	-----------	-------------	-------------------

**Client Sample Description** 6135 5 / Building Trades / Sink Faucet  
**Collected:** 4/17/2021 10:46:00 AM  
**Lab ID:** 012104137-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/4/2021 20:54 KB
-------	------	----	-----------	-------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104137  
 CustomerID: ERIE51  
 CustomerPO: B41235-21  
 ProjectID:

Attn: **Warren Ristine**  
**Erie 1 BOCES**  
**355 Harlem Road**  
**West Seneca, NY 14224**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 4/22/2021 09:40 AM

Project: **Potter Career & Tech. Ctr.**

**Analytical Results**

**Client Sample Description** 6136 **Collected:** 4/17/2021 **Lab ID:** 012104137-0006  
 6 / Building Trades / Sink Faucet 10:46:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.03	1.00 µg/L	5/4/2021 KB	5/4/2021 20:56 KB

**Client Sample Description** 6137 **Collected:** 4/17/2021 **Lab ID:** 012104137-0007  
 7 / Building Trades / Sink Faucet 10:46:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/4/2021 21:03 KB

**Client Sample Description** 6138 **Collected:** 4/17/2021 **Lab ID:** 012104137-0008  
 8 / Rm. 106 / Sink Faucet 10:50:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/4/2021 21:05 KB

**Client Sample Description** 6139 **Collected:** 4/17/2021 **Lab ID:** 012104137-0009  
 9 / Rm. 106 / Sink Faucet 10:50:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	23.1	1.00 µg/L	5/4/2021 KB	5/4/2021 21:08 KB

**Client Sample Description** 6140 **Collected:** 4/17/2021 **Lab ID:** 012104137-0010  
 10 / Mens Room / Sink Faucet 10:51:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	4.13	1.00 µg/L	5/4/2021 KB	5/4/2021 21:10 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104137  
 CustomerID: ERIE51  
 CustomerPO: B41235-21  
 ProjectID:

Attn: **Warren Ristine**  
**Erie 1 BOCES**  
**355 Harlem Road**  
**West Seneca, NY 14224**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 4/22/2021 09:40 AM

Project: **Potter Career & Tech. Ctr.**

**Analytical Results**

**Client Sample Description** 6141  
 11 / Mens Room / Sink Faucet  
**Collected:** 4/17/2021 10:51:00 AM  
**Lab ID:** 012104137-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.70	1.00 µg/L	5/4/2021 KB	5/4/2021 21:12 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6142  
 12 / 110 / Sink Faucet  
**Collected:** 4/17/2021 10:52:00 AM  
**Lab ID:** 012104137-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/4/2021 21:19 KB
-------	------	----	-----------	-------------	-------------------

**Client Sample Description** 6143  
 13 / 110 / Sink Faucet  
**Collected:** 4/17/2021 10:52:00 AM  
**Lab ID:** 012104137-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/4/2021 21:21 KB
-------	------	----	-----------	-------------	-------------------

**Client Sample Description** 6144  
 14 / Ladies Room Main Hall / Sink Faucet  
**Collected:** 4/17/2021 10:54:00 AM  
**Lab ID:** 012104137-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.61	1.00 µg/L	5/4/2021 KB	5/4/2021 21:24 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6145  
 15 / Ladies Room Main Hall / Sink Faucet  
**Collected:** 4/17/2021 10:54:00 AM  
**Lab ID:** 012104137-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	2.53	1.00 µg/L	5/4/2021 KB	5/4/2021 21:31 KB
-------	------	------	-----------	-------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104137  
 CustomerID: ERIE51  
 CustomerPO: B41235-21  
 ProjectID:

Attn: **Warren Ristine**  
**Erie 1 BOCES**  
**355 Harlem Road**  
**West Seneca, NY 14224**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 4/22/2021 09:40 AM

Project: **Potter Career & Tech. Ctr.**

**Analytical Results**

**Client Sample Description** 6146 **Collected:** 4/17/2021 **Lab ID:** 012104137-0016  
 16 / Ladies Room Main Hall / Sink Faucet 10:56:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	6.28	1.00 µg/L	5/4/2021 KB	5/4/2021 21:33 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6147 **Collected:** 4/17/2021 **Lab ID:** 012104137-0017  
 17 / Slop Room Main Hall / Sink Faucet 10:55:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.75	1.00 µg/L	5/4/2021 KB	5/4/2021 21:35 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6148 **Collected:** 4/17/2021 **Lab ID:** 012104137-0018  
 18 / Mens Room Main Hall / Sink Faucet 10:57:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/4/2021 21:38 KB
-------	------	----	-----------	-------------	-------------------

**Client Sample Description** 6149 **Collected:** 4/17/2021 **Lab ID:** 012104137-0019  
 19 / Mens Room Main Hall / Sink Faucet 10:57:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/4/2021 21:40 KB
-------	------	----	-----------	-------------	-------------------

**Client Sample Description** 6150 **Collected:** 4/17/2021 **Lab ID:** 012104137-0020  
 20 / 112 Main Hall / Sink Faucet 11:04:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	3.25	1.00 µg/L	5/4/2021 KB	5/4/2021 21:42 KB
-------	------	------	-----------	-------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104137  
 CustomerID: ERIE51  
 CustomerPO: B41235-21  
 ProjectID:

Attn: **Warren Ristine**  
**Erie 1 BOCES**  
**355 Harlem Road**  
**West Seneca, NY 14224**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 4/22/2021 09:40 AM

Project: **Potter Career & Tech. Ctr.**

**Analytical Results**

**Client Sample Description** 6151  
 21 / 112 Main Hall / Sink Faucet  
**Collected:** 4/17/2021 11:04:00 AM  
**Lab ID:** 012104137-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.71	1.00 µg/L	5/4/2021 KB	5/4/2021 21:52 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6152  
 22 / 112 Ice Machine / Ice Machine  
**Collected:** 4/17/2021 11:05:00 AM  
**Lab ID:** 012104137-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/4/2021 22:03 KB
-------	------	----	-----------	-------------	-------------------

**Client Sample Description** 6153  
 23 / 112 Pot Washer / Shower Head  
**Collected:** 4/17/2021 11:05:00 AM  
**Lab ID:** 012104137-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/4/2021 22:06 KB
-------	------	----	-----------	-------------	-------------------

**Client Sample Description** 6154  
 24 / 112 Hand Sink / Sink Faucet  
**Collected:** 4/17/2021 11:05:00 AM  
**Lab ID:** 012104137-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/4/2021 22:08 KB
-------	------	----	-----------	-------------	-------------------

**Client Sample Description** 6155  
 25 / 112 Hand Sink / Sink Faucet  
**Collected:** 4/17/2021 11:06:00 AM  
**Lab ID:** 012104137-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/4/2021 22:10 KB
-------	------	----	-----------	-------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104137  
 CustomerID: ERIE51  
 CustomerPO: B41235-21  
 ProjectID:

Attn: **Warren Ristine**  
**Erie 1 BOCES**  
**355 Harlem Road**  
**West Seneca, NY 14224**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 4/22/2021 09:40 AM

Project: **Potter Career & Tech. Ctr.**

**Analytical Results**

**Client Sample Description** 6156 **Collected:** 4/17/2021 **Lab ID:** 012104137-0026  
 26 / 112 Rear Sink / Sink Faucet 11:07:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/4/2021 22:13 KB
-------	------	----	-----------	-------------	-------------------

**Client Sample Description** 6157 **Collected:** 4/17/2021 **Lab ID:** 012104137-0027  
 27 / 112, 112 Rear Sink / Sink Faucet 11:07:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/4/2021 22:15 KB
-------	------	----	-----------	-------------	-------------------

**Client Sample Description** 6158 **Collected:** 4/17/2021 **Lab ID:** 012104137-0028  
 28 / 112 Stove Sink / Sink Faucet 11:08:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	4.05	1.00 µg/L	5/4/2021 KB	5/4/2021 22:17 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6159 **Collected:** 4/17/2021 **Lab ID:** 012104137-0029  
 29 / 112 Stove Sink / Sink Faucet 11:09:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	4.32	1.00 µg/L	5/4/2021 KB	5/4/2021 22:19 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6160 **Collected:** 4/17/2021 **Lab ID:** 012104137-0030  
 30 / 112 Hand Sink / Sink Faucet 11:10:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.24	1.00 µg/L	5/4/2021 KB	5/4/2021 22:26 KB
-------	------	------	-----------	-------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104137

CustomerID: ERIE51

CustomerPO: B41235-21

ProjectID:

Attn: **Warren Ristine**  
**Erie 1 BOCES**  
**355 Harlem Road**  
**West Seneca, NY 14224**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 4/22/2021 09:40 AM

Project: **Potter Career & Tech. Ctr.****Analytical Results**

**Client Sample Description** 6161  
 31 / 112 Sink / Sink Faucet  
**Collected:** 4/17/2021 11:12:00 AM  
**Lab ID:** 012104137-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.87	1.00 µg/L	5/4/2021 KB	5/4/2021 22:29 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6162  
 32 / 112 Sink / Sink Faucet  
**Collected:** 4/17/2021 11:10:00 AM  
**Lab ID:** 012104137-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	2.39	1.00 µg/L	5/4/2021 KB	5/4/2021 22:36 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6163  
 33 / 154 Sink / Sink Faucet  
**Collected:** 4/17/2021 11:15:00 AM  
**Lab ID:** 012104137-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	2.37	1.00 µg/L	5/4/2021 KB	5/4/2021 22:38 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6164  
 34 / 154 Sink / Sink Faucet  
**Collected:** 4/17/2021 11:17:00 AM  
**Lab ID:** 012104137-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.99	1.00 µg/L	5/4/2021 KB	5/4/2021 22:40 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6165  
 35 / 154 Sink / Sink Faucet  
**Collected:** 4/17/2021 11:17:00 AM  
**Lab ID:** 012104137-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	2.76	1.00 µg/L	5/4/2021 KB	5/4/2021 22:43 KB
-------	------	------	-----------	-------------	-------------------



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	012104137
CustomerID:	ERIE51
CustomerPO:	B41235-21
ProjectID:	

Attn: **Warren Ristine**  
**Erie 1 BOCES**  
**355 Harlem Road**  
**West Seneca, NY 14224**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 4/22/2021 09:40 AM

Project: **Potter Career & Tech. Ctr.****Analytical Results**

**Client Sample Description** 6166  
36 / 155 Sink / Sink Faucet  
**Collected:** 4/17/2021 11:17:00 AM  
**Lab ID:** 012104137-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	2.81	1.00 µg/L	5/4/2021 KB	5/4/2021 22:45 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6167  
37 / 155 Sink / Sink Faucet  
**Collected:** 4/17/2021 11:20:00 AM  
**Lab ID:** 012104137-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.84	1.00 µg/L	5/4/2021 KB	5/4/2021 22:47 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6168  
38 / 155 Sink / Sink Faucet  
**Collected:** 4/17/2021 11:20:00 AM  
**Lab ID:** 012104137-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.75	1.00 µg/L	5/4/2021 KB	5/4/2021 22:59 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6169  
39 / Slop Room Auto End / Sink Faucet  
**Collected:** 4/17/2021 11:20:00 AM  
**Lab ID:** 012104137-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	5.65	1.00 µg/L	5/4/2021 KB	5/4/2021 23:01 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6170  
40 / Bottle Filler Auto / Water Cooler  
**Collected:** 4/17/2021 11:25:00 AM  
**Lab ID:** 012104137-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/4/2021 23:04 KB
-------	------	----	-----------	-------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104137  
 CustomerID: ERIE51  
 CustomerPO: B41235-21  
 ProjectID:

Attn: **Warren Ristine**  
**Erie 1 BOCES**  
**355 Harlem Road**  
**West Seneca, NY 14224**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 4/22/2021 09:40 AM

Project: **Potter Career & Tech. Ctr.**

**Analytical Results**

**Client Sample Description** 6171  
 41 / Auto LAV / Sink Faucet  
**Collected:** 4/17/2021 11:26:00 AM  
**Lab ID:** 012104137-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.33	1.00 µg/L	5/4/2021 KB	5/4/2021 23:13 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6172  
 42 / Auto LAV / Sink Faucet  
**Collected:** 4/17/2021 11:26:00 AM  
**Lab ID:** 012104137-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.21	1.00 µg/L	5/4/2021 KB	5/4/2021 23:24 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6173  
 43 / Auto LAV / Sink Faucet  
**Collected:** 4/17/2021 11:26:00 AM  
**Lab ID:** 012104137-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.41	1.00 µg/L	5/4/2021 KB	5/4/2021 23:27 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6174  
 44 / 156 Sink / Sink Faucet  
**Collected:** 4/17/2021 11:26:00 AM  
**Lab ID:** 012104137-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	11.7	1.00 µg/L	5/4/2021 KB	5/4/2021 23:29 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6175  
 45 / 156 Sink / Sink Faucet  
**Collected:** 4/17/2021 11:27:00 AM  
**Lab ID:** 012104137-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.83	1.00 µg/L	5/4/2021 KB	5/4/2021 23:31 KB
-------	------	------	-----------	-------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104137  
 CustomerID: ERIE51  
 CustomerPO: B41235-21  
 ProjectID:

Attn: **Warren Ristine**  
**Erie 1 BOCES**  
**355 Harlem Road**  
**West Seneca, NY 14224**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 4/22/2021 09:40 AM

Project: **Potter Career & Tech. Ctr.**

**Analytical Results**

**Client Sample Description** 6176  
 46 / 156 Sink / Sink Faucet  
**Collected:** 4/17/2021 11:30:00 AM  
**Lab ID:** 012104137-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	21.7	1.00 µg/L	5/4/2021 KB	5/4/2021 23:34 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6177  
 47 / 157 / Sink Faucet  
**Collected:** 4/17/2021 11:30:00 AM  
**Lab ID:** 012104137-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	8.19	1.00 µg/L	5/4/2021 KB	5/4/2021 23:36 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6178  
 48 / Lactation Room / Sink Faucet  
**Collected:** 4/17/2021 11:35:00 AM  
**Lab ID:** 012104137-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	82.8	1.00 µg/L	5/4/2021 KB	5/4/2021 23:38 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6179  
 49 / 158 / Sink Faucet  
**Collected:** 4/17/2021 11:38:00 AM  
**Lab ID:** 012104137-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	13.3	1.00 µg/L	5/4/2021 KB	5/4/2021 23:41 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6180  
 50 / 158 Sink / Sink Faucet  
**Collected:** 4/17/2021 11:38:00 AM  
**Lab ID:** 012104137-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	34.9	1.00 µg/L	5/4/2021 KB	5/4/2021 23:43 KB
-------	------	------	-----------	-------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104137  
 CustomerID: ERIE51  
 CustomerPO: B41235-21  
 ProjectID:

Attn: **Warren Ristine**  
**Erie 1 BOCES**  
**355 Harlem Road**  
**West Seneca, NY 14224**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 4/22/2021 09:40 AM

Project: **Potter Career & Tech. Ctr.**

**Analytical Results**

**Client Sample Description** 6181  
 51 / 158 Sink / Sink Faucet  
**Collected:** 4/17/2021 11:38:00 AM  
**Lab ID:** 012104137-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	10.2	1.00 µg/L	5/4/2021 KB	5/4/2021 23:50 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6182  
 52 / 158 Slop Sink / Sink Faucet  
**Collected:** 4/17/2021 11:40:00 AM  
**Lab ID:** 012104137-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	12.9	1.00 µg/L	5/4/2021 KB	5/4/2021 23:57 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6183  
 53 / Skills Store / Sink Faucet  
**Collected:** 4/17/2021 11:40:00 AM  
**Lab ID:** 012104137-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.18	1.00 µg/L	5/4/2021 KB	5/4/2021 23:59 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6184  
 54 / Office / Sink Faucet  
**Collected:** 4/17/2021 11:45:00 AM  
**Lab ID:** 012104137-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.85	1.00 µg/L	5/4/2021 KB	5/5/2021 00:02 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6185  
 55 / Faculty Rm / Sink Faucet  
**Collected:** 4/17/2021 11:45:00 AM  
**Lab ID:** 012104137-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/5/2021 00:04 KB
-------	------	----	-----------	-------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104137  
 CustomerID: ERIE51  
 CustomerPO: B41235-21  
 ProjectID:

Attn: **Warren Ristine**  
**Erie 1 BOCES**  
**355 Harlem Road**  
**West Seneca, NY 14224**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 4/22/2021 09:40 AM

Project: **Potter Career & Tech. Ctr.**

**Analytical Results**

**Client Sample Description** 6186 **Collected:** 4/17/2021 **Lab ID:** 012104137-0056  
 56 / Bottle Office Filler Main Hall / Water Cooler 11:45:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/5/2021 00:06 KB

**Client Sample Description** 6187 **Collected:** 4/17/2021 **Lab ID:** 012104137-0057  
 57 / Faculty Ladies Room / Sink Faucet 11:46:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/5/2021 00:09 KB

**Client Sample Description** 6188 **Collected:** 4/17/2021 **Lab ID:** 012104137-0058  
 58 / Faculty Ladies Room / Sink Faucet 11:46:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/5/2021 00:11 KB

**Client Sample Description** 6189 **Collected:** 4/17/2021 **Lab ID:** 012104137-0059  
 59 / Faculty Ladies Room / Sink Faucet 11:46:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/5/2021 00:18 KB

**Client Sample Description** 6190 **Collected:** 4/17/2021 **Lab ID:** 012104137-0060  
 60 / Faculty Mens Room / Sink Faucet 11:47:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/5/2021 00:20 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104137  
 CustomerID: ERIE51  
 CustomerPO: B41235-21  
 ProjectID:

Attn: **Warren Ristine**  
**Erie 1 BOCES**  
**355 Harlem Road**  
**West Seneca, NY 14224**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 4/22/2021 09:40 AM

Project: **Potter Career & Tech. Ctr.**

**Analytical Results**

**Client Sample Description** 6191  
 61 / Faculty Mens Room / Sink Faucet  
**Collected:** 4/17/2021 11:47:00 AM  
**Lab ID:** 012104137-0061

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/5/2021 00:29 KB
-------	------	----	-----------	-------------	-------------------

**Client Sample Description** 6192  
 62 / 2nd Floor IT Dep. LAV / Sink Faucet  
**Collected:** 4/17/2021 12:04:00 PM  
**Lab ID:** 012104137-0062

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/5/2021 00:36 KB
-------	------	----	-----------	-------------	-------------------

**Client Sample Description** 6193  
 63 / 2nd Floor Cust. Closet / Sink Faucet  
**Collected:** 4/17/2021 12:04:00 PM  
**Lab ID:** 012104137-0063

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	19.4	1.00 µg/L	5/4/2021 KB	5/5/2021 00:39 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6194  
 64 / 2nd Floor Ladies Room / Sink Faucet  
**Collected:** 4/17/2021 12:05:00 PM  
**Lab ID:** 012104137-0064

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.35	1.00 µg/L	5/4/2021 KB	5/5/2021 00:46 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6195  
 65 / 2nd Floor Ladies Room / Sink Faucet  
**Collected:** 4/17/2021 12:06:00 PM  
**Lab ID:** 012104137-0065

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	3.20	1.00 µg/L	5/4/2021 KB	5/5/2021 00:48 KB
-------	------	------	-----------	-------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104137  
 CustomerID: ERIE51  
 CustomerPO: B41235-21  
 ProjectID:

Attn: **Warren Ristine**  
**Erie 1 BOCES**  
**355 Harlem Road**  
**West Seneca, NY 14224**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 4/22/2021 09:40 AM

Project: **Potter Career & Tech. Ctr.**

**Analytical Results**

**Client Sample Description** 6196 **Collected:** 4/17/2021 **Lab ID:** 012104137-0066  
 66 / 2nd Floor Ladies Room / Sink Faucet 12:06:00 PM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	4.66	1.00 µg/L	5/4/2021 KB	5/5/2021 00:50 KB

**Client Sample Description** 6197 **Collected:** 4/17/2021 **Lab ID:** 012104137-0067  
 67 / 2nd Floor Mens Room / Sink Faucet 12:06:00 PM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.41	1.00 µg/L	5/4/2021 KB	5/5/2021 00:53 KB

**Client Sample Description** 6198 **Collected:** 4/17/2021 **Lab ID:** 012104137-0068  
 68 / 2nd Floor Mens Room / Sink Faucet 12:06:00 PM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/5/2021 00:55 KB

**Client Sample Description** 6199 **Collected:** 4/17/2021 **Lab ID:** 012104137-0069  
 69 / Rm 204 / Sink Faucet 12:07:00 PM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	11.3	1.00 µg/L	5/4/2021 KB	5/5/2021 00:57 KB

**Client Sample Description** 6222 **Collected:** 4/28/2021 **Lab ID:** 012104137-0070  
 70 / 206 Esthetics Room / Sink Faucet 6:10:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.37	1.00 µg/L	5/5/2021 KB	5/5/2021 18:21 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104137  
 CustomerID: ERIE51  
 CustomerPO: B41235-21  
 ProjectID:

Attn: **Warren Ristine**  
**Erie 1 BOCES**  
**355 Harlem Road**  
**West Seneca, NY 14224**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 4/22/2021 09:40 AM

Project: **Potter Career & Tech. Ctr.**

**Analytical Results**

**Client Sample Description** 6201  
 71 / 206 Rear Faucet / Sink Faucet  
**Collected:** 4/17/2021 12:08:00 PM  
**Lab ID:** 012104137-0071

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.41	1.00 µg/L	5/4/2021 KB	5/5/2021 01:00 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6202  
 72 / 206 Hair Wash / Shower Head  
**Collected:** 4/17/2021 12:14:00 PM  
**Lab ID:** 012104137-0072

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	2.46	1.00 µg/L	5/4/2021 KB	5/5/2021 01:02 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6203  
 73 / 206 Hair Wash / Shower Head  
**Collected:** 4/17/2021 12:14:00 PM  
**Lab ID:** 012104137-0073

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/5/2021 01:14 KB
-------	------	----	-----------	-------------	-------------------

**Client Sample Description** 6204  
 74 / 206 Hair Wash / Shower Head  
**Collected:** 4/17/2021 12:14:00 PM  
**Lab ID:** 012104137-0074

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/5/2021 01:16 KB
-------	------	----	-----------	-------------	-------------------

**Client Sample Description** 6205  
 75 / 206 Hair Wash / Shower Head  
**Collected:** 4/17/2021 12:14:00 PM  
**Lab ID:** 012104137-0075

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/5/2021 01:18 KB
-------	------	----	-----------	-------------	-------------------



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104137  
 CustomerID: ERIE51  
 CustomerPO: B41235-21  
 ProjectID:

Attn: **Warren Ristine**  
**Erie 1 BOCES**  
**355 Harlem Road**  
**West Seneca, NY 14224**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 4/22/2021 09:40 AM

Project: **Potter Career & Tech. Ctr.**

**Analytical Results**

**Client Sample Description** 6206  
 76 / 206 Hair Wash / Shower Head  
**Collected:** 4/17/2021 12:14:00 PM  
**Lab ID:** 012104137-0076

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	5/4/2021 KB	5/5/2021 01:21 KB
-------	------	----	-----------	-------------	-------------------

**Client Sample Description** 6207  
 77 / 207 Sink / Sink Faucet  
**Collected:** 4/17/2021 12:16:00 PM  
**Lab ID:** 012104137-0077

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.26	1.00 µg/L	5/4/2021 KB	5/5/2021 01:23 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6208  
 78 / 207 Hair Wash / Shower Head  
**Collected:** 4/17/2021 12:16:00 PM  
**Lab ID:** 012104137-0078

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.08	1.00 µg/L	5/4/2021 KB	5/5/2021 01:25 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6209  
 79 / 207 Hair Wash / Shower Head  
**Collected:** 4/17/2021 12:16:00 PM  
**Lab ID:** 012104137-0079

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.46	1.00 µg/L	5/4/2021 KB	5/5/2021 01:27 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6210  
 80 / 207 Hair Wash / Shower Head  
**Collected:** 4/17/2021 12:17:00 PM  
**Lab ID:** 012104137-0080

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	3.65	1.00 µg/L	5/4/2021 KB	5/5/2021 01:30 KB
-------	------	------	-----------	-------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104137  
 CustomerID: ERIE51  
 CustomerPO: B41235-21  
 ProjectID:

Attn: **Warren Ristine**  
**Erie 1 BOCES**  
**355 Harlem Road**  
**West Seneca, NY 14224**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 4/22/2021 09:40 AM

Project: **Potter Career & Tech. Ctr.**

**Analytical Results**

**Client Sample Description** 6211  
 81 / 207 Hair Wash / Shower Head  
**Collected:** 4/17/2021 12:17:00 PM  
**Lab ID:** 012104137-0081

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.46	1.00 µg/L	5/4/2021 KB	5/5/2021 01:32 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6212  
 82 / 207 Hair Wash / Shower Head  
**Collected:** 4/17/2021 12:18:00 PM  
**Lab ID:** 012104137-0082

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.38	1.00 µg/L	5/4/2021 KB	5/5/2021 01:51 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6213  
 83 / 207-208 Laundry / Sink Faucet  
**Collected:** 4/17/2021 12:18:00 PM  
**Lab ID:** 012104137-0083

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.52	1.00 µg/L	5/4/2021 KB	5/5/2021 01:58 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6214  
 84 / 208 Sink / Sink Faucet  
**Collected:** 4/17/2021 12:20:00 PM  
**Lab ID:** 012104137-0084

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	8.87	1.00 µg/L	5/4/2021 KB	5/5/2021 02:00 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6215  
 85 / 208 Hair Wash / Shower Head  
**Collected:** 4/17/2021 12:20:00 PM  
**Lab ID:** 012104137-0085

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	2.09	1.00 µg/L	5/4/2021 KB	5/5/2021 02:02 KB
-------	------	------	-----------	-------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104137  
 CustomerID: ERIE51  
 CustomerPO: B41235-21  
 ProjectID:

Attn: **Warren Ristine**  
**Erie 1 BOCES**  
**355 Harlem Road**  
**West Seneca, NY 14224**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 4/22/2021 09:40 AM

Project: **Potter Career & Tech. Ctr.**

**Analytical Results**

**Client Sample Description** 6216  
 86 / 208 Hair Wash / Shower Head  
**Collected:** 4/17/2021 12:20:00 PM  
**Lab ID:** 012104137-0086

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	2.81	1.00 µg/L	5/4/2021 KB	5/5/2021 02:09 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6217  
 87 / 208 Hair Wash / Shower Head  
**Collected:** 4/17/2021 12:20:00 PM  
**Lab ID:** 012104137-0087

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.66	1.00 µg/L	5/4/2021 KB	5/5/2021 02:12 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6218  
 88 / 208 Hair Wash / Shower Head  
**Collected:** 4/17/2021 12:20:00 PM  
**Lab ID:** 012104137-0088

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.36	1.00 µg/L	5/4/2021 KB	5/5/2021 02:14 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6219  
 89 / 208 Hair Wash / Shower Head  
**Collected:** 4/17/2021 12:21:00 PM  
**Lab ID:** 012104137-0089

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	2.63	1.00 µg/L	5/4/2021 KB	5/5/2021 02:16 KB
-------	------	------	-----------	-------------	-------------------

**Client Sample Description** 6220  
 90 / 210 / Sink Faucet  
**Collected:** 4/17/2021 12:22:00 PM  
**Lab ID:** 012104137-0090

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	1.86	1.00 µg/L	5/4/2021 KB	5/5/2021 02:19 KB
-------	------	------	-----------	-------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012104137

CustomerID: ERIE51

CustomerPO: B41235-21

ProjectID:

Attn: **Warren Ristine**  
**Erie 1 BOCES**  
**355 Harlem Road**  
**West Seneca, NY 14224**

Phone: (716) 821-7440  
 Fax: (716) 821-7037  
 Received: 4/22/2021 09:40 AM

Project: **Potter Career & Tech. Ctr.****Analytical Results**

**Client Sample Description** 6221 **Collected:** 4/17/2021 **Lab ID:** 012104137-0091  
 91 / 211 / Sink Faucet 12:25:00 PM

<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date &amp; Analyst</i>	<i>Analysis Date &amp; Analyst</i>
<b>METALS</b>					
200.8	Lead	6.56	1.00 µg/L	5/4/2021 KB	5/5/2021 02:21 KB

**Definitions:**

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results